

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3230-1328:117 Page 1 of 1

CATEGORY: Leakage Dampers

LISTEE: Air Balance, 7301 International Drive, Holland OH 43528
Contact: Chuck Schneider (419) 865-5000 FAX (419) 865-1375

DESIGN: Model FS2C250 leakage damper. Intended for installation only in specific code accepted corridor ceiling constructions that are used for Tunnel Corridors that provide access and egress from or within the building. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Class II Leakage rated.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and UL label.

APPROVAL: Listed as Class II leakage rated damper for use in 1hour fire rated wall designs to be employed for ceiling constructions under specified conditions. Degradation test temperature is 250° F. Refer to listee's Installation Instruction Manual for details.

07-21-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**